

MUNICIPAL CORPORATION OF GREATER MUMBAI

No. CHE/DP/110 / Gen dated 2019-20

CIRCULAR DCPR2034 C-8

Subject: Guide Lines for of parking layout proposals

1) PLANS:

Parking Layout proposal shall be submitted showing Block Plan (Scale 1 :500, 1:40 or to the scale as per T.P. Scheme), Location Plan (Scale 1:4000 / 1:2500) the required parking statement as per DCPR 2034 , Plans (Scale 1: 1 00 preferably and 1:200 in case of bigger layouts only) showing parking floors such as ground floor, stilt floor, basement floors, parking / podium floors and floor next to parking floors, cross sections showing the details of parking/podium floors and floor next to parking / podium floor (Particularly, showing all level differences such as basement top, ground level, stilt level, underground water tank top, rewas of stair case, staircase mid landing, elevation features projection, where maneuvering is proposed) along with road level, ground level of the plot at the entry, exit points of vehicle and cross sections of mechanized parking systems ,if any.

- 1.1) Ground floor plan shall contain compound wall, entry/ exit gate, chain link gate, sliding gate, type of access to the plot such as layout road, existing road, D. P. Road, etc. with detail of width of road , L.O.S. / paved L.O.S. and other reservations , amenities if any, required front open space line to be shown in dotted line.
- 1.2) Each parking floor plan shall contain minimum clear dimensions of drive way, angular dimensions of driveway at the corners of the plot and at the turning direction of driveways.
- 1.3) All R.C.C. / Structural members such as columns, lifts sheer walls, etc. shall be shown in dark colour.
- 1.4) Statement showing the area of side & rear open space of the building and area consumed by the proposed car parking spaces as per provision of Regulation 44 of DCPR 2034.
- 1.5) Slope of the ramp, width of ramp and length of the ramp at the center of driveway (Length of the ramp shall be shown at the center of inner driveway in case of two-way maneuvering) shall be shown on plan.
- 1.6) In case of proposal under Regulation 33 (18) of DCPR -2034, the conditions insisted by Jt. C. P. (Traffic) & by the Committee for approval of the proposals under Regulation 33 (18) of DCPR - 2034 shall be incorporated in the parking layout for obtaining NOC of Dy.Ch.E.(Traffic) department.

2) DRIVEWAY:

- 2.1 Driveway proposed shall be free of any obstructions and width as mentioned below shall be provided.
 - 2.1.1) The width of driveway for one way maneuvering shall be minimum 3.00 mts. in straight alignment & 3.90 mts. width shall be provided at turning portions for proper maneuverings of the vehicles.

- 2.1.2) The width of driveway for two way maneuvering shall be minimum 6.00 mts. in straight alignment & 7.50 mts. at the turning portions for proper maneuvering of the vehicles.
- 2.1.3) Minimum 3.75 mts. wide driveway shall be provided for one way maneuvering in straight alignment & 4.65 mts. at the turning portions and 7.50 mts. wide driveway shall be provided for two way maneuvering in straight alignment & 9.00 mts. at the turning portions shall be provided for transport vehicles & Ambulance.
- 2.2) Minimum 3.50 mts. wide gate shall be provided in case of single entry or exit and 6.00 mts. wide gate for entry & exit.
- 2.3) Unobstructed Passage of minimum width of 3.00 mts. shall be provided from entry gate up to entrance lobby / staircase of the building for ingress & egress of the vehicles up to entrance of the building, if the parking spaces are proposed in the said passage.
- 2.4) In the driveway portion where 'U' turn is proposed, minimum 5.50 mts. of inner diameter of the turning portion ('U' turn) shall be provided.
- 2.5) In the driveway portion, the minimum 2.40 m. head room shall be provided from the bottom of slab/ beam/ any projection/ ramp/ revas projection of staircase cantilever parking etc.
- 2.6) If the surface angular parking is proposed along the one-way driveway minimum 3.6 m width shall be provided for proper ingress and egress of vehicle in the parking space.

3) **PARKING SPACES:**

- 3.1) **SIZE OF PARKING SPACES** The size of parking spaces shown on plan shall be as per the provisions of regulation 44(1) of DCPR 2034.
- 3.1.1) For motor vehicles : -
Big cars = 2.50 mts. x 5.50 mts. (shall be shown in green colour) In case of parking spaces for motor vehicles, up to 50% of the prescribed parking spaces may be of size 2.30 mts. x 4.50 mts. as per Regulation 44(1) of DCPR 2034.
- 3.1.2) For Transport Vehicles: 3.75 mts. x 7.50 mts. as per Regulation 44(1) of DCPR 2034. (shall be shown in red colour)
- 3.1.3) For Ambulance: 4.00 mts. x 10.00 mts. as per 44(2) Table 21 of DCPR 2034. (shall be shown in red colour)
- 3.1.4) In case of 33(18) proposals, PPL / MCGM parking spaces shall be shown in blue colour.
- 3.1.5) Mechanical stack parking shall be shown in green hatched.
- 3.1.6) School Bus parking may be provided as per Note (iv) below Table 21 of regulation 44(2) of DCPR 2034 of size 3.75 mts X 7.5 mts.
- 3.1.7) Two Wheeler parking: 3.0 sq.m. with least dimension minimum 1.2 m as per regulation 44(1) (ii).
- 3.2) Car parking spaces shall not be proposed on

- (1) Required front open space.
- (2) L.O.S.
- (3) Ventilation openings for Basements.
- (4) Manhole / Openings / Chambers of under-ground water tank / Fire fighting tank.

3.3 DISTANCE REQUIRED FOR PARKING SPACE:

- 3.3.1) There is no necessity to provide minimum distance on either side of parking for ingress/ egress of vehicle if parking spaces are proposed in row along the driveway or alternate parking.
- 3.3.2) Tandem Parking: The required sizes of parking spaces may be allowed directly one behind the other with 2.50 m. wide parking bay.
- 3.4) Parking spaces for Differently Able shall be proposed only for public building as per Regulation 39 (3.2) and as under
 - 3.4.1) Surface parking shall be provided near ground floor entrance or on immediate upper floor entrance for the physically handicapped persons with maximum travel distance of 30 mt. from building entrance.
 - 3.4.2) The size of parking bay shall be minimum 3.60 mt. x 5.50 mt.
 - 3.4.3) The information stating that the space is reserved for wheel chair users shall be conspicuously displayed.

4) CAR LIFT:

- 4.1) The minimum size of car lift hoist -way shall be 3.30 mts. x 6.00mts. to accommodate all kinds of vehicles.
- 4.2) Minimum 5.00 mts. unobstructed open space shall be provided in front of the car lift /hoist for proper maneuvering of vehicles on the respective parking floor.
- 4.3) If the car hoists are proposed, then provision of separate passenger lift shall be made nearby.
- 4.4) If the driveway is proposed through the Car Lift, then the clear opening of the car lift shall be minimum 3.30 mts. wide. (The details of the Car Lift and required hoist-way as per Manufacturer's specification shall be submitted.)
- 4.5) Number of car lifts requirement shall be as per provisions of DCPR- 2034

5) RAMP:

- 5.1) Ramps shall be proposed as per provisions of Regulation 37(16) of DCPR 2034.
- 5.2) The maximum 45.00 mts. continuous ramp length shall be permitted.(Mid-Landing minimum of 6.00 mts. in length shall be provided at the interval of maximum every 45.00 mts. travel distance.)